

“पेयजल व्यवस्था प्रमाण पत्र”

प्रमाणित किया जाता है कि डी. ए. वी. मु. प. स्कूल परचेली कटेकल्याण, जिला दन्तेवाड़ा में छात्र/छात्राओं एवं कर्मचारियों के पेयजल हेतु स्वच्छ पानी की उपलब्धता है यह प्रमाण पत्र दिनांक 4.1.04.1.2.02.4... से ...3.1.1.0.3.1.2.0.2.5.. तक के लिए वैध है।

PRINCIPAL
DAV MUKHYAMANTRI PUBLIC SCHOOL
PARCHELLI DANTEWADA (C.G.)

मुख्य कार्यपालक अधिकारी
जनपद पंचायत कटेकल्याण
जनपद पंचायत कटेकल्याण
जिला द. व. दन्तेवाड़ा (छ.ग.)



Format Id- DWTL/PHED/DNT/F/4.1

District Water Testing Laboratory
Public Health Engineering Division Dantewada Chhattisgarh

Near Old Collectorate Sub-Dn.-2, PIN-494449

Email- eedan-phe-cg@mail.nic.in

Test Report
Group - Drinking Water

Certificate No. TC- 10377

Sender's Name and Address: DAV Mukhyamantri Public School, Mokhpal	ULR No.:- TC103772200000234F	Sample Collected by - DAV Mukhyamantri Public School		
	Sender's letter no.	-	Sender's letter Date	25.02.2024
	DL Receipt No.	02/24/234	DL Received date	25.02.2024
	Date of analysis started	25.02.2024	Date of analysis completed	26.02.2024

Sample Details-

No.	Block & District	Village & Panchayat	Sample ID	Location/Source No.
1	कटेकल्याण	परचेली	442	DAV Mukhyamantri Public School, Mokhpal
2				
3				
4				
5				
6				
7				
8				


Details of parameters, their test methods, units and specifications as per IS:3025

No.	Characteristics	Test method IS:3025		Unit of Measurement	As Per BIS -10500:2012 For Drinking Water		Results									
		Method	Part no.		Acceptable Limit	Permissible Limit	1	2	3	4	5	6	7	8		
1	2	3	4	5	6	7	Sample ID → 442									
1	Turbidity	IS:3025	Part -10	NTU	1.0	5.0	0									
2	pH	IS:3025	Part -11	pH scale	6.5 - 8.5	6.5 -8.5	6.56									
3	Total Alkalinity as CaCO ₃	IS:3025	Part -23	mg/l	200	600	43.05									
4	Chloride as Cl ⁻	IS:3025	Part- 32	mg/l	250	1000	21.45									
5	Total Hardness as CaCO ₃	IS:3025	Part -21	mg/l	200	600	62.31									
6	Calcium as Ca ⁺⁺	IS:3025	Part -40	mg/l	75	200	19.31									
7	Magnesium as Mg ⁺⁺	IS:3025	Part -46	mg/l	30	100	3.41									
8	Total Dissolved Solid	IS:3025	Part -16	mg/l	500	2000	224									
9	Taste	IS:3025	Part -8		Agreeable	Agreeable	Agreeable									
10	Odour	IS:3025	Part -5		Agreeable	Agreeable	Agreeable									
11	Color	IS:3025	Part -4	cu	5	15	3									

- 1 This report should not be produced partly or full without approval of signatory authority of legal purposes
- 2 It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 7 above which the sources will have to be rejected.
- 3 The results refer only to tested samples and parameters tested.
- 4 Samples will be stored for a period of 10 days from the date of issue of report.
- 5 This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- 6 The Laboratory does not give interpretation on Test result PASSED / FAILED
- 7 1. Results apply to the sample as received
2. Sampling not done by the Laboratory Staff

Issue No.-----234-----/Lab/ Date- :16.10.2022

Page- of


Nikhil Kumar Kanwar
Assistant Engineer
Authorised Signatory(NABL)

End of Test Report